

Meeting Minutes – Sewer Commission
Northfield Town Hall
69 Main Street, Northfield MA
Oct 20th, 2022 – 4:30 pm - Conference Room First Floor

Call to Order/Attendees: Chair – Dan Gray (DG), Tom Walker (TW), Karen Boudreau (KB), Chief Operator - Isaac Golding (IG), Michele Turner (MT) (when requested)

Present: Dan Gray (DG), Tom Walker (TW), Karen Boudreau (KB), Chief Operator - Isaac Golding (IG)

Called to order 4:47 pm, DG arrived at 4:52 pm

Business:

- Aerator Pump Motor is down.

Operator Report: Isaac

10/18/2022 Email from Isaac.

1. Repair old pump.
2. New pump or new motor? Applied Dynamics.
3. Update the aerator basin as part of the ACOP – estimate from IG about 100k.

KB called an emergency meeting.

Can it be rebuilt?

Applied to get a tech at the plant. IG to contact Joel at App Dynamics about the aerator. IG emailed DEP.

What is the overall direction from the Sewer Comm?

Discussion:

With colder temps, 2 aerators are needed more than warm weather. The SC and IG will see if Applied Dynamics can fix the pump and what the total cost will be. It is a 10 HP aerator. It was not caused by the lightning strike.

TW will transport back to safe on return shipping when needed.

IG and KB are researching other firms that make these aerators. KB found one firm in Manassas Va.

Vote to move forward to see about repairs. Motion by KB, 2nd by TW, all in favor.

Next Meeting is: 11/16/2022

Adjourned: 5:25 pm

11/16/2022 12:49 PM

Approved:

Signature: _____

Date:

Signature: _____

Date:

Signature: *Steven White* 12/7/22 Date:

Signature: *Ann Bourdrea* 12/7/22 Date:

The meeting minutes are being posted in compliance with Massachusetts Open Meeting Law.