



P.O. Box 320325
Boston, MA 02132
Voice: 617. 469 .2172
eFax: 617. 419. 1163
Cellular: 617. 308. 2172

Beth S. Greenblatt
Managing Director

July 19, 2021

Town of Northfield
Mr. Stephen Seredynski, Chair
Northfield Planning Board
69 Main Street
Northfield, MA 01360

RE: Special Permit Conditions for Pine Meadow Road Solar Array "B", Assessor Map 54, Lot B5 and Map 55, Lot B1

Dear Chairman Seredynski :

Beacon Integrated Solutions ("Beacon") was engaged by the Town of Northfield, Planning Board to develop Conditions in connection with the Decision approving the Special Permit and Site Plan filed by BWC Pine Meadow Brook, LLC. The Special Permit Conditions presented herein pertain to Pine Meadow Road Solar Array B.

Background:

On February 8, 2021, Beacon submitted its findings resulting from its review of the Special Permit application and Site Plan submitted by Field Engineering on behalf of BWC Pine Meadow Brook, LLC ("Applicant") to construct a large-scale, dual-use ~4.3-megawatt DC/2-megawatt AC solar photovoltaic array, paired with 2-megawatt DC-coupled lithium-ion battery (the "Project"). The Project seeks classification as a Dual-Use (solar and agricultural) Project under the Solar Massachusetts Renewable Target ("SMART") Program.

On May 20, 2021, the Northfield Planning Board conducted its deliberative session following three Public Hearings. The initial Public Hearing was held on February 18, 2021, followed by two continued Public Hearings on March 18 and April 15, 2021. The Public Hearing was closed for Pine Meadow Road Solar Array B on February 18, 2021.

In the aforementioned report to the Planning Board, Beacon noted several Conditions for the Planning Board's consideration. Additional considerations were offered during the various Public Hearings, Planning Board deliberations and follow-on comments from Planning Board members.

We present the following recommended Conditions for consideration by the Planning Board.

Administrative:

1. Throughout the entire operation of the Project, Applicant shall notify and provide documentation to the Planning Board within sixty (60) days of any assignment, transfer or sale of BWC Pine Meadow Brook LLC. Such documentation shall include the then-current identification information of the owner/operator, along with a Certificate of Good Standing from the Commonwealth of Massachusetts.
2. Within thirty (30) days after naming the Engineering, Procurement and Construction (“EPC”) firm it selects to construct the Project, Applicant shall provide the Planning Board all required identification information, along with a Certificate of Good Standing from the Commonwealth of Massachusetts.
3. Within sixty (60) days prior to applying for the Building Permit, Applicant shall provide to the Planning Board a Decommissioning Plan which fully addresses the procedures Applicant will undertake to remove and restore the areas impacted by the Project.

Such Decommissioning Plan shall at minimum address:

- a. the approach and methods to be deployed for equipment removal that minimizes disturbance, damage and/or degradation of the vegetation, soils and landscape,
 - b. the type of replacement soils and proposed revegetation plan,
 - c. seasonal timing considerations that impact agricultural prosperity,
 - d. a decommissioning budget specific to the scope of work defined. Such budget shall include a contingency of fifteen (15) percent and an annual cost-of-living escalator for the entire life of the Project,
 - e. the form of decommissioning assurance which shall be limited to a funded escrow account, an irrevocable bond or letter of credit from a financial institution lawfully authorized to do business in Massachusetts and having a rating no lower than A- (Excellent), and
 - f. documentation that the Decommissioning Plan has been accepted by the Property Owner.
4. Within thirty (30) days of the issuance of the Special Permit Decision, Applicant shall amend, and provide to the Planning Board, its Post Construction Stormwater Operation and Maintenance Plan to include annual monitoring of the catch basins along Pine Meadow Road in the vicinity of the Project and annual snow management requirements.
 5. Within sixty (60) days prior to applying for the Building Permit, Applicant shall provide to the Planning Board written documentation from the Northfield Fire Department approving the fire protection and suppression systems, in addition to any protocols required to mitigate and/or address any fluids release in connection with the lithium-ion battery storage system.

General:

1. All work on the site shall be permitted during the Work Hours defined as 7:00 AM through 5:00 PM, Monday through Friday. Any desired change of Work Hours shall be requested in writing to, and approved by, the Town Administrator at least forty-eight (48) hours prior to such desired change. The Town Administrator shall have full authority to temporarily modify the Work Hours.
2. Deliveries of major equipment and supplies, and deliveries made by tractor-trailers or other large vehicles shall only be allowed during Work Hours.
3. Year-round access to the equipment pads shall be provided to Town public safety officials.
4. Applicant shall use general industry best practices to minimize dust, debris and noise during the construction and operations/maintenance periods.
5. Applicant shall provide support to Town Department of Public Works for cleaning out catch basins on Pine Meadow Road in the vicinity of the Project in advance of construction.
6. Vehicle idling shall be kept to a minimum.
7. Whenever possible, local labor and materials shall be used.

Zoning and Setback:

1. As required in the Zoning Bylaw, Applicant shall reconfigure and relocate gravel access roads and security fencing to be sited outside of the one hundred (100) foot property line setback. Applicant shall provide the Planning Board with an updated Site Plan within thirty (30) days of the issuance of the Special Permit Decision. Alternatively, prior to applying for the Building Permit, Applicant may seek a variance from the Zoning Board of Appeals to remain within the one hundred (100) foot property line setback.

Agricultural Preservation:

1. Applicant shall undertake all pre-construction, construction and post-construction activities in accordance with the SMART Program Pre-Determination Application Agricultural Plan as approved by the Massachusetts Department of Energy Resources ("DOER"), in consultation with the University of Massachusetts Center for Agriculture, Food and the Environment and Clean Energy Extension, and the Massachusetts Department of Agricultural Resources ("MDAR"), and shall provide the Planning Board with any reports prepared, or inspections conducted as required by the above entities documenting compliance with the Agricultural Plan.

2. Soil excavation, trenching and grading shall be minimized. Soils excavated shall be properly stored and redistributed on the site. Any added soils brought to the site as a result of excavation or vegetation disturbance shall be replaced with similar soils.
3. Construction methods shall be undertaken to minimize compaction of the soils, including the use of low compaction impact equipment. Decompaction of soils shall be required post construction as needed.

Vegetation and Visual Mitigation:

1. Utility poles and aboveground wiring shall be sited to minimize visual impacts from abutters. Tree removal shall be minimized.
2. Pollinator habitats shall be considered in areas under Applicant's control where existing vegetation has been disturbed provided that such pollinator habitat does not diminish or limit the on-going intended agricultural use of the soil. If a pollinator habitat is not feasible, a seed mix comprised of low growing cool and warm seasonal grasses and legumes shall be considered.
3. Applicant shall collaborate with the landowner to support additional pollinator habitats in areas not subject to the Site Plan review, provided that such pollinator habitat does not diminish or limit the agricultural use of the soil.
4. No less than forty-five (45) days prior to applying for the Building Permit, Applicant shall provide to the Planning Board a Pollinator Habitat Feasibility Report addressing the feasibility and approach to integrating a pollinator habitat into the Project and/or surrounding land.

Archaeological Impact:

1. Within thirty (30) days of issuance of the Special Permit Decision, a copy of the fully executed agreement between the Atowi Project and Applicant shall be provided to the Planning Board.
2. Within forty-five (45) days of issuance of the Special Permit Decision, an archaeologist shall be engaged by Applicant to:
 - a. prepare all documents and conduct all required studies and sampling in connection with the filing with the Massachusetts Historical Commission ("MHC"), including Phase 1A and 1B studies, and
 - b. serve as a technical advisor to the Northfield Historical Commission.
3. A Project Notification Form ("PNF") shall be submitted to the MHC to support the filing requirements with MHC.

4. Applicant shall provide the Planning Board with a copy of the Phase 1A and 1B findings and any Response or Advisory issued by MHC within thirty (30) days of issuance by MHC.
5. Applicant shall comply with the Northfield Archaeology Accountability Policy.

Eversource Interconnection Siting:

1. Applicant shall obtain Planning Board approval prior to applying for the Building Permit for any material changes to the utility interconnection design and construction plan, as updated on the May 10, 2021 Site Plan and approved by the Planning Board, including location, material disturbance of vegetation or soils, pole placement, overhead wiring and underground conduits.

Project Modifications:

1. Applicant shall obtain Planning Board approval prior to applying for the Building Permit for any material changes to the Project, including but not limited to:
 - a. capacity, location, area or equipment height,
 - b. equipment changes impacting noise or contaminants and ground disturbance,
 - c. changes required as a result of any additional geotechnical studies, and
 - d. changes required to comply with the findings from the archaeological studies and sampling, or in connection with any findings of the MHC.

Post-Construction:

1. Applicant shall demonstrate on an annual basis compliance with its Post Construction Stormwater Operation and Maintenance Plan, as amended.
2. Within sixty (60) days prior to Commercial Operations, Applicant shall provide safety and emergency training to Town staff, public safety and first responder personnel.
3. On an annual basis, Applicant shall document the continued agricultural use of the property by providing a copy of the Annual Report filed with the DOER as required under the Massachusetts SMART Program. Such documentation shall, at minimum, include the productivity of the crop(s) and herd, including pounds harvested and/or grazed, herd size growth, success of the crops, and potential changes. Such documentation shall be provided to the Planning Board within thirty (30) days of the filing submission to the Massachusetts SMART Program.
4. Within thirty (30) days of receiving the Certificate of Occupancy from the Building Inspector, Applicant shall provide to the Planning Board:

- a. as-built documentation stamped by a Massachusetts licensed engineer
- b. safety manuals and emergency protocols
- c. documentation from the Northfield Fire Department approving fire suppression systems and emergency protocols
- d. proof of insurance in amounts as required by the Town
- e. decommissioning surety instrument in amounts and form approved by the Planning Board

Beacon very much appreciates the opportunity to support the Northfield Planning Board in its review of this Project. If you have any questions or need additional information, please do not hesitate to contact me directly at 617-469-2172.

Best regards,

Beth S. Greenblatt

Beth S. Greenblatt